Hiawatha!™

Site Plan Review:

Water Department

Site plan review: 1460 North Center Point Road

Commercial

12/9/2019

1. Water main: 12" PVC water main located on North Center Point Road.
2. Hydrant Location: City hydrant located at North Center Point Road. Site plan represents additional hydrants being install on the property.
3. Water Demand in this area: This area has adequate flow for this occupancy
4. Cross Connection Protection: Shall be installed per the City of Hiawatha Plumbing Code.
5. Water Service: 2" minimum service line from main to curb stop is required. One service line, one-meter, multiple meters require a meter room with access from the outside or separate service lines, each then could be 1" services.

Matthew J. Rerkin

Water Superintendent

Its ok

WATER DEPARTMENT • P.O. BOX 485 • HIAWATHA, IA 52233-0485 • PHONE (319) 393-5556 • FAX (319) 393-1516